

ABE

A-B-E Laboratory
7596-B Bath Pike
Bath, Pa 18014

Certificate of Water Analysis

Pennsylvania Department of Environmental Protection
(DEP) Certified Lab ID # 48-108

[
 Mailing Address
 123 Mian Street
 Anytown, PA 18343
]

Sampled By: B. Leiby/BPG Inspection

Property where collected if different from mailing

	No. 1	No. 2	No. 3	No. 4	No. 5
Source					
Place Collected	Bathrm Faucet				
Date Collected	06/05/17				
Time Collected	14:15				
Total Coliform / 100ml	0				
E.Coli / 100ml	0				

Chemical Analysis	Result	DEP/EPA Standards
N Nitrate	<2.5 mg/L	10
N Nitrite	<0.1 mg/L	1
Total Nitrate/Nitrite	<2.5 mg/L	10
First Draw Lead	<0.001 mg/L	.015

Notes:

Results are reported on an "as received" basis. This report may only be reproduced in full. Additions to, deletions from, or other changes to this report are not permitted. (05/06). ABE Lab is certified for the analysis of Total Coliform, E.Coli, N Nitrate, N Nitrite, Alkalinity, TDS, Calcium Hardness, pH. Lead testing is subcontracted to a state certified lab.(05/17).

The above Coliform Result(s) DO meet the DEP/EPA standards
 The above Chemical Result(s) DO meet the DEP/EPA standards

Approved By: *BS Ripu* Date 6/10/2017



A-B-E Laboratory
7596-B Bath Pike
Bath, Pa 18014

Phone: (610) 837-7721

Certificate of Water Analysis

Pennsylvania Department of Environmental Protection
(DEP) Certified Lab ID # 48-108

Mailing Address: 123 Mian Street
Anytown, PA 18343

Sampled By: B. Leiby/BPG Inspection

Property where collected if different from mailing

	No. 1	No. 2	No. 3	No. 4	No. 5
Source					
Place Collected	Bathrm Faucet				
Date Collected	06/05/17				
Time Collected	14:15				
Total Coliform / 100ml					
E.Coli / 100ml					

Chemical Analysis	Result	DEP/EPA Standards
pH	7.6	6.5-8.5
Hardness	None Detected	Report
Iron	.06 mg/L	.3
Manganese	<.01 mg/L	.05
Total Solids	496 mg/L	500

Notes:

Results are reported on an "as received" basis. This report may only be reproduced in full. Additions to, deletions from, or other changes to this report are not permitted. (05/06). ABE Lab is certified for the analysis of Total Coliform, E.Coli, N Nitrate, N Nitrite, Alkalinity, TDS, Calcium Hardness, pH. Lead testing is subcontracted to a state certified lab.(05/17).

The above Coliform Result(s) _____ meet the DEP/EPA standards
The above Chemical Result(s) DO meet the DEP/EPA standards

Approved By: *BS Ripa* Date 6/10/2017